

# Ground Level Play Requirements

Play areas are required to provide diversity in experiences at ground level for all participants. One of each type of play experience that exists in a play area must also be made accessible.

Number of Elevated Play Activities provided, equal to or greater than:	Min. number of Ground Level Play Activities required to be on accessible route	Min. number of Ground Level Play Types required to be on accessible route
0	0	0
1	0	0
2	1	1
5	2	2
8	3	3
11	4	3
14	5	3
17	6	3
20	7	4
23	8	4
26	Calculate*	5

\* For 26 or more Elevated Activities: 8 + (1 for each additional 3 over 25, or fraction thereof)




## ADA Evaluation

With the introduction of the Americans with Disabilities Act (ADA) in 1990 and the subsequent adoption of standards specific to play areas, accessibility has become an important issue to everyone.

Below is a chart evaluating the play area for your proposed playground. This evaluation assumes that proper resilient surfacing within the play site and an accessible route of travel to the play area and equipment are a part of this proposal package. Also, that no other play equipment is in the site.

This play area meets current ADA requirements.

### Play Area for 2-5 Year Olds



	Elevated Activities	Ground Level Activities	Ground Level Play Types
Quantity Present in Site	6	6	4
Quantity on Accessible Route	6	6	4
Quantity Required to be Accessible	3	4	4