

Play Area Accessibility Checklist

KEEP A COPY OF THIS FORM FOR YOUR RECORDS.

Play Areas for 2-5 year olds and 5-12 year olds, as well as geographically separated play areas, should be evaluated separately.

Site Name Tiverton Town Farm
 Age Group 5-12
 Date December 8, 2020
 Prepared By Diane Molina

Item Number / Name	Play Activity	Elevated	Accessible	Ground	Accessible	Ground Level Play Type
PCT210601-xx01	Banister Bars	•	•			
Same as PCT210601-xx02	Tube Net	•	•			
	Interior Climbing Wall w/ Cleats	•	•			
	Interior Climbing Wall w/ Cleats	•	•			
	Orbs & UFO Climber	•	•			
	Exterior Climbing Net	•	•			
	Modular Slide (Plastic)	•	•			
	Interior Climbing Wall w/ Cleats	•	•			
	Wackie Bridge	•	•			
	Crag Climber	•				
	Interior Climbing Wall w/ Cleats	•				
	Slidepole	•				
	Interior Climbing Wall w/ Cleats	•				
	Interior Climbing Wall w/ Cleats	•				
	Tube Slide (Plastic)	•				
	Tic-Tac-Toe			•	•	Experimenting
	Turning Bar			•	•	Training
	Talk Tubes			•	•	Experimenting
	Hammock			•	•	Gathering
	Playshell Seat			•		Gathering
	Double Playshell Seats			•	•	Gathering
	Labyrinth Panel			•		Experimenting
BLX4103 BLOQX 3				•	•	Climbing/Crawling
GXY Custom Spica				•	•	Spinning
ELE400024 Spinner Bowl				•	•	Spinning
GXY960 Supernova				•	•	Balancing
COR825001 Ocean Arch				•	•	Climbing/Crawling
KSW920-	Belt Swing			•	•	Swinging
	Belt Swing			•	•	Swinging
	Basket Swing			•	•	Swinging
M88 Double Cableway Robinia Flat				•	•	Training

TOTALS	15	9	16	14	7
	Elevated Activities	Accessible Elevated	Ground Level Activities	Accessible Ground Level	DIFFERENT Ground Level Play Types

Accessible Elevated Activities Required 8

50% of elevated activities must be accessible.

Accessible Ground Level Activities Required 7

See table for accessibility requirements.

Accessible Ground Level Play Types Required 7

See table and compare to total number of different ground level play types. The larger number is the number of ground level play types that must be accessible.

NOTE: If a ground level play type is present but not accessible and it is the ONLY ONE, an additional ground level play component with the same play type MUST BE PROVIDED IN THE PLAY AREA TO OFFER EQUITY. (ADA2010, Chapter 2: Scoping Requirements, 240.2.1.1 Minimum Number and Types)

This form is intended to assist the evaluation of accessibility for outdoor play facilities. This form does not represent all factors required for an accessible play facility contained in the regulations, and therefore is not a guarantee, test, or confirmation of accessibility. Requirements for accessibility include appropriate accessible routes, maneuvering spaces and clear floor and ground spaces. Play components must include appropriate transfer heights and/or be accessed by ramp where appropriate. Providing and maintaining accessibility is the responsibility of the Play Facility Owner.


ADA Evaluation

With the introduction of the Americans with Disabilities Act (ADA) in 1990 and the subsequent adoption of standards specific to play areas, accessibility has become an important issue to everyone.

Below is a chart evaluating the play area for your proposed playground. This evaluation assumes that proper resilient surfacing within the play site and an accessible route of travel to the play area and equipment are a part of this proposal package. Also, that no other play equipment is in the site.

This play area meets current ADA requirements.

Play Area for 2-5 Year Olds



	Elevated Activities	Ground Level Activities	Ground Level Play Types
Quantity Present in Site	15	16	7
Quantity on Accessible Route	9	14	7
Quantity Required to be Accessible	8	7	7

Ground Level Play Requirements

Play areas are required to provide diversity in experiences at ground level for all participants. One of each type of play experience that exists in a play area must also be made accessible.

Number of Elevated Play Activities provided, equal to or greater than:	Min. number of Ground Level Play Activities required to be on accessible route	Min. number of Ground Level Play Types required to be on accessible route
0	0	0
1	0	0
2	1	1
5	2	2
8	3	3
11	4	3
14	5	3
17	6	3
20	7	4
23	8	4
26	Calculate*	5

* For 26 or more Elevated Activities: 8 + (1 for each additional 3 over 25, or fraction thereof)